



Office of the Manager, Planning Services

William J. King, AMCT, MCIP, RPP
Manager, Planning Services

July 12, 2017

Mr. David French
Town of Kingsville
2021 Division Road North
Kingsville, Ontario
N9Y 2Y9

Dear Mr. French:

**RE: ZBA-14-2016 and SPA-14-2016, 1298466 Ontario Ltd., Part Lot 275,
Concession NTR, North Side of County Road No. 34, East of Cameron
Sideroad, Municipal Number 364**

Please be advised that the County has reviewed the aforementioned application and the comments provided are engineering related only. This application has not been reviewed from a planning perspective. The subject lands have frontage on County Road No. 34.

The Applicant will be required to comply with the following County Road regulations:

County By-Law Number 2481 – A By-Law to Provide for the Protection of Highways and to Provide for the Installation of Entrance Ways.

County By-Law Number 2480 – A By-Law of the Corporation of the County of Essex to Regulate the Location of Buildings and Structures on Land Adjacent to County Roads.

The minimum setback for any proposed structures on this property must be 85 feet from the centre of the right of way of County Road 34. Permits are necessary for any changes to existing entrances or structures, or the construction of new entrances or structures.

We are requesting a copy of the Decision of the aforementioned application. Thank you for your assistance and cooperation in this matter.

Sincerely,

A handwritten signature in blue ink, appearing to read "W. King", written over the word "Sincerely,".

William J. King, AMCT, MCIP, RPP
Manager, Planning Services