



planning@erca.org

P.519.776.5209

F.519.776.8688

360 Fairview Avenue West
Suite 311, Essex, ON N8M 1Y6

July 22, 2021

Mr. Robert Brown, Manager of Planning Services
Planning & Development Services Department
The Corporation of the Town of Kingsville
2021 Division Road North
Kingsville Ontario, N9Y 2Y9

Dear Mr. Brown:

RE: Application for Site Plan Control SPA-23-2021
19 DIMAR DR
ARN 371129000027216; PIN: 751460157
Applicant: NELLO HOLDINGS INC

The following is provided as a result of our review of Application for Site Plan Control SPA-23-2021. The subject land is a 0.73 ha (1.80 ac.) vacant industrial parcel. The applicant is proposing to construct a warehouse with office space on the property as shown on the applicant's Site Plan drawing. The proposed building would be constructed in up to three phases; Phase 1 is 650 sq. m (7,000 sq. ft.) of warehouse and 195 sq. m (2,100 sq. ft.) of office. Phase 2 is 975.5 sq. m (10,500 sq. ft.) of warehouse and Phase 3 is 1,338 sq. m (14,400 sq. ft.) of warehouse.

DELEGATED RESPONSIBILITY TO REPRESENT THE PROVINCIAL INTEREST IN NATURAL HAZARDS AND REGULATORY RESPONSIBILITIES ASSOCIATED WITH THE CONSERVATION AUTHORITIES ACT

The following comments reflect our role as representing the provincial interest in natural hazards as outlined by Section 3.1 of the Provincial Policy Statement of the *Planning Act* as well as our regulatory role as defined by Section 28 of the *Conservation Authorities Act*.

We have reviewed our floodline mapping for this area and it has been determined this site is not located within a regulated area that is under the jurisdiction of the ERCA (Section 28 of the *Conservation Authorities Act*). As a result, a permit is not required from ERCA for issues related to Section 28 of the *Conservation Authorities Act*, Development, Interference with Wetlands and Alteration to Shorelines and Watercourses Regulation under the *Conservations Authorities Act*, (Ontario Regulation No. 158/06).

WATERSHED BASED RESOURCE MANAGEMENT AGENCY

The following comments are provided in an advisory capacity as a public commenting body on matters related to watershed management.



Mr. Brown
July 22, 2021

SECTION 1.6.6.7 Stormwater Management (PPS, 2020)

ERCA has concerns with the potential impact of the quality and quantity of runoff in the downstream watercourse due to the proposed development on this site. ERCA recommends that stormwater quality and stormwater quantity will need to be addressed up to and including the 1:100 year storm event and be in accordance with the guidance provided by the Stormwater Management Planning and Guidance Manual, prepared by the Ministry of the Environment (MOE, March 2003) and the "Windsor-Essex Region Stormwater Management Standards Manual".

We therefore request inclusion of the following conditions in the Development Agreement:

1. That the developer undertakes an engineering analysis to identify stormwater quality and quantity measures as necessary to control any increases in flows in downstream watercourses, up to and including the 1:100 year design storm, to the satisfaction of the Municipality and the Essex Region Conservation Authority.
2. That the developer installs stormwater management measures identified above, as part of the development of the site, to the satisfaction of the Municipality and the Essex Region Conservation Authority.
3. That the developer obtains the necessary permit or clearance from the Essex Region Conservation Authority prior to undertaking site alterations and/or construction activities.

The applicant must obtain a development clearance from ERCA.

PLANNING ADVISORY SERVICE TO PLANNING AUTHORITIES - NATURAL HERITAGE POLICIES OF THE PPS, 2020

The following comments are provided from our perspective as an advisory service provider to the Planning Authority on matters related to natural heritage and natural heritage systems as outlined in Section 2.1 of the Provincial Policy Statement of the *Planning Act*. The comments in this section do not necessarily represent the provincial position and are advisory in nature for the consideration of the Planning Authority.

The subject property is not within or adjacent to any natural heritage feature that may meet the criteria for significance as defined by the PPS. Based on our review, we have no objection to the application with respect to the natural heritage policies of the PPS.

FINAL RECOMMENDATION

With the review of background information and aerial photograph, the applicant must provide a stormwater management plan to the



Mr. Brown
July 22, 2021

satisfaction of the Town of Kingsville and the Essex Region Conservation Authority. The applicant must obtain a development clearance from ERCA.

If you have any questions or require any additional information, please contact the undersigned.

Sincerely,



Vitra Chodha, E.P
Resource Planner
/vc

